COMMERCIAL TESTING COMPANY
1215 South Hamilton Street • Dalton, Georgia 30720
Telephone (706) 278–3935 • Facsimile (706) 278–3936

**Report Number 26–04180**

**Arte**
**Senator A. Jeurissenlaan 1210**
**3520 Zonhoven, Belgium**

**Test Number 6345–1674.9**
**April 24, 2026**

**Washability**

**Test Method:** The material was tested in accordance with ASTM International standard classification F793/F793M–15, *Wall Covering by Use Characteristics*, which covers the classification of wall covering according to its serviceability in use. A sample from an area with as many different printed colors as possible, as well as the ground, is tested in a Gardner washability machine equipped with a WG-2000C cellulose sponge saturated with the specified detergent solution. At the end of the requisite number of cycles, the machine is stopped, the specimen removed, and rinsed under running water. After drying, the specimen shall show no evidence of appreciable damage to the printed or ground surface. Areas of localized wear clearly related to wrinkles is ignored.

**Material Tested:** The client submitted a sample of wallcovering identified as **INDIENNE – KASHMIR**.

**Test Data:** The client requested the sample be exposed to 100 cycles, the requisite number for a Type II classification.

**Test Result:** The material tested, **INDIENNE – KASHMIR**, meets Type II requirements for washability in accordance with ASTM F793/F793M–15. Overall classification can not be based on a single performance property.

**Commercial Testing Company**

*(Authorized Signature)*

Date Sample Received: April 3, 2026
Date Specimen Prepared: April 3, 2026
Date Test Performed: April 13, 2026
Date of Report: April 24, 2026

*This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. The test results presented in this report apply only to the samples tested and are not necessarily indicative of apparent identical or similar materials. Sample selection and identification were provided by the client. A sampling plan, if described in the referenced standard, was not necessarily followed. This report, or the name of Commercial Testing Company, shall not be used under any circumstance in advertising to the general public.*