



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

JW/2302

Gent

2026-02-23

Certification report 20/2302

1. Description of the material:

type	Type 5: Decorative wall covering consisting of: Non-woven + 10 mm mousse
Total mass	730-760 g/m ²

2. Test executed:

Sound absorption measurement according to ISO 10543-2

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee	our reference	Gent	page
Arte nv	JW/2302	2026-02-23	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

NRC = 20%

Related commercial names to this product group	BABYLON ECLIPSE BLACK & WHITE: <u>Articles:</u> 43510, 43530, 43550, 43511, 43531, 43551 EINIGMA: Select, Flex INTRIGUE: Rosace OBJET SPECTRA: Carrelage TERRA: Arcilla
The obtained classification is based on the next test report(s)	Centexbel 20.02515.01 dated 22-06-20 Centexbel 23.05002.01 dated 19-10-23
Validity of the certificate	2030-06-19

PhD. Jo Wynendaele

Consultant Floor and Wall coverings