

Mrs. Nadine Joosten
Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference	our reference	Gent
-	PW/2193	2022-03-03

Certification report 19/2193

1. Description of the wall covering:

Product family	Type 4a: Three dimensional Wallcovering (foam 5mm)
Total mass	Ca. 600-955 g/m ²

2. Test results:

EN ISO 11925-2 (exposure=30s) EN 13823
--

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

addressee	our reference	Gent	page
Arte nv	PW/2193	2022-03-03	2

C - s1, d0

field of application: glued on end-use substrates having a density of 1350 kg/m3 or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group	ECLIPSE BLACK & WHITE: Charm ENIGMA: Charm INTRIGUE: Caisson ICONS: Curve MEMENTO MOOOI: Memic Moth, Pogo Goat MOOOI: Dwarf Rhino, Dodo Pavone, Flying Coral Fish MOOOI TOKYO BLUE: Shoji Blossom MOOOI Spring 2021: Mimic Moth SPECTRA: Parquet, Cannage, Caisson VELVETEEN YALA
The obtained classification is based on the next test reports	AITEX: 2019AN2689 AITEX: 2020AN2201
Validity of the certificate	2024-10-14

Petra Wittevrongel

Product Certifier