



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

JW/667

Gent

2026-06-17

Certification report 18/667

1. Description of the wall covering:

Product family	Type 06c: Decorative wall covering consisting of: Non-woven substrate + Fabric
Total mass	370-1000 g/m ²

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

addressee

Arte nv

our reference

JW/667

Gent

2026-06-17

page

2

D - s1, d0

field of application: glued (starch glue applied at the rate of 1kg/6m²) on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group

Allures: Éclosion
Les Tapissieres : Collines
Takare : Crane

The obtained classification is based on the next test reports

Aitex: 2024AN2454 issued 20/11/2024
Aitex: 2026AN0788 issued 12/04/2026
Aitex: 2026AN1098 issued 21/05/2026

Validity of the certificate

19-11-2029

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

