



**Arte nv**  
**Industriezone "De Waerde"**  
**Senator A. Jeurissenlaan 1210**  
**B-3520 Zonhoven**

**Your message - reference**

-

**our reference**

PW/676

**Gent**

2022-03-03

Certification report 22/676

---

## 1. Description of the wall covering:

<b>Product family</b>	Type 06e: Decorative wall covering made of a non woven backing layer and fabric
<b>Total mass</b>	335 g/m <sup>2</sup>

## 2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT •** Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)

**VAT •** BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

<b>addressee</b>	<b>our reference</b>	<b>Gent</b>	<b>page</b>
Arte nv	PW/676	2022-03-03	2

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

<b>D - s1, d0</b>
-------------------

*field of application: glued on end-use substrates having a density of 1350 kg/m<sup>3</sup> or higher and classified A2-s1, d0 or A1.*

<b>Related commercial names to this product group</b>	LES THERMES: Orizzonte
<b>The obtained classification is based on the next test reports</b>	CREPIM: DO-21-3459\A-R1 dated 08-12-21
<b>Validity of the certificate</b>	2026-12-07

Petra Wittevrongel

Product Certifier

