



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

JW/676

Gent

2026-06-17

Certification report 22/676

1. Description of the wall covering:

Product family	Type 06e: Decorative wall covering made of a nonwoven backing layer and a surface made of 36% CO + 20% PAN + 20% WO + 20% PES + 2% PA
Total mass	335 -615 g/m ²

2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee

Arte nv

our reference

JW/676

Gent

2026-06-17

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

D - s1, d0

field of application: glued on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1, d0 or A1.

Related commercial names to this product group

DCO & PNR : Sierra Nevada
Les Thermes : Orizzonte

The obtained classification is based on the next test reports

AITEX: 2026AN0790 issued on 13/04/2026

Validity of the certificate

12/04/2031

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

