



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

jw/745

Gent

2023-06-23

Certification report 19/745

1. Description of the wall covering:

Product family	Type 02: Wallcovering with natural materials and decorative elements
Total mass	226 g/m ² - 1.150 g/m ²

2. Test results:

Classification according to EN13501-1:2007+A1 (2009)

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee	our reference	Gent	page
Arte nv	jw/745	2023-06-23	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

<div>B - s1, d0</div> <p><i>field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.</i></p>	
Related commercial names to this product group	Artisan Bark Cloth Boracay Cantala: Papyrus-Raphia Carabao Expedition: Java Heliodor Icons: Waffle Weave-Rattan Insero Ligna: Scope Kharga: Ténéré Les Forêts: Infini, Éclat, Ajoura, Ruban Manovo Marqueterie MEMENTO MOOOI: Queen Cobra-Golden Tiger MOOOI: Armoured Bear-Bearded Leopard MOOOI Spring 2021: Queen Cobra MOOOI Tokyo Blue: Lucky's Os Oculaire Osmanthus: Gardens of Okayama, Chasu, Tatami, Kudzu, Sambe, Line Revera: Align Takara : Spirit, Air, Feather, Harmony Timber Wildwalk: Ferox
The obtained classification is based on the next test reports	AITEX: 2022AN6725 issued 07-09-2022 AITEX: 2022AN6394 issued 18-07-2022 AITEX: 2019AN0390 issued 08-03-2019
Validity of the certificate	07/03/2024

Jo Wynendaele, PhD
 Consultant Floor and Wall Coverings

