COMMERCIAL TESTING COMPANY
1215 South Hamilton Street • Dalton, Georgia 30720
Telephone (706) 278–3935 • Facsimile (706) 278–3936

Report Number 24–12061

Arte
Senator A. Jeurissenlaan 1210
B–3520 Zonhoven, Belgium

Test Number 6091–8168
December 18, 2024

Washability

Test Method: The material was tested in accordance with ASTM International standard classification F793/F793M–15, *Wall Covering by Use Characteristics*, which covers the classification of wall covering according to its serviceability in use. A sample from an area with as many different printed colors as possible, as well as the ground, is tested in a Gardner washability machine equipped with a WG-2000C cellulose sponge saturated with the specified detergent solution. At the end of the requisite number of cycles, the machine is stopped, the specimen removed, and rinsed under running water. After drying, the specimen shall show no evidence of appreciable damage to the printed or ground surface. Areas of localized wear clearly related to wrinkles is ignored.

Material Tested: The client submitted a sample of vinyl wallcovering identified as **Sculptura Piante**.

Test Data: The client requested the sample be exposed to 100 cycles, the requisite number for a Type II classification.

Test Result: The material tested, **Sculptura Piante**, meets Type II requirements for washability in accordance with ASTM F793/F793M–15. Overall classification can not be based on a single performance property.

Commercial Testing Company

Deviane Jackson

(Authorized Signature)

Date Sample Received: October 18, 2024
Date Specimen Prepared: October 18, 2024
Date Test Performed: December 6, 2024
Date of Report: December 18, 2024

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. The test results presented in this report apply only to the samples tested and are not necessarily indicative of apparent identical or similar materials. Sample selection and identification were provided by the client. A sampling plan, if described in the referenced standard, was not necessarily followed. This report, or the name of Commercial Testing Company, shall not be used under any circumstance in advertising to the general public.