

Arte nv Industriezone "De Waerde" Senator A. Jeurissenlaan 1210 B-3520 Zonhoven

Your message - reference	our reference	Gent
-	JW/720	2023-11-06

Certification report 19/720

1. Description of the wall covering:

Product family	Type 03: Vinyl wallcovering with water based ink
Total mass	Ca 330 - 605 g/m²

2. Tests executed:

EN ISO 11925-2 (exposure=30s)	EN 13823

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

addressee	our reference	Gent	page
Arte nv	JW/720	2023-11-06	2

 $B-s2,\ d0$ field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m3 or higher and classified A2-s1,d0 or A1.

acrostly of reservey,	
Related commercial names to this product group	Alaya: Katan Silk Antigua Atelier Avalon Curiosa Expedition: Tasar, Sumatra, Eri Figura Focus Gitane: Nongo, Janela, Cuadro, Ondas Lino Manila: Botanic, Spiral, Edge, Atlas, Fiore Monsoon Monsoon 2.0 Sculptura Selva Signature Textura
The obtained classification is based on the next test reports	Aitex: 2018AN2975 dated 22-10-2018 Aitex: 2019AN0394 dated 07-03-2019

Validity of the certificate

2024-04-01

Jo Wynendaele, PhD Consultant Floor and Wall Coverings