Arte nv
Industriezone ''De Waerde''
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference	our reference	Gent
-	JW/2602	2026-03-12

Certification report 24/2602

1. Description of the wall covering:

Product family	Type 06a: Wallcovering with textile
Total mass	350 g/m² - 650 g/m²

2. Test results:

Classification according to EN13501-1:2007+A1 (2009)

EN ISO 11925-2 (exposure=30s)	EN 13823

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

C - s1, d0

field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m3 or higher and classified A2-s1,d0 or A1.

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.
Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be
GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be
VAT • BE 0459.218.289 • **IBAN** • BE 44 2100 4729 6545 • **BIC** • GEBABEBB

Related commercial names to this product group	Boutique: Riverbank Le Couturier: Majesto Les Tapissiers: Riverbank Paleo : Copán
The obtained classification is based on the next test reports	AITEX: 2024AN0355 dd 2024-02-28 AITEX: 2024AN0357 dd 2024-03-25
Validity of the certificate	2029-02-28

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings